

Steve,  
Kim and Kevin,

The town inspection sheet doesn't fit the spa, so here is what I need to inspect.

Any buried electrical  
Any plumbing that will be buried  
All grounding as per instructions  
All electrical work  
placement of spa prior to backfilling  
final inspection which will include the required fencing, etc. with lockable entrance.

David H Lersch  
Plainfield Building Inspector