



Map 10 Lot 1000 Town Garage

SEWAGE DISPOSAL SYSTEM DATA			
NUMBER OF BEDROOMS	_____	GALS./DAY	500
PERC. RATE	5 MIN./IN.	HOLE DEPTH	2.5' DATE 5/13/74
ABSORPTION AREA	225	SQ. FT.	
SEPTIC TANK	750	GALS.	CONC. <input checked="" type="checkbox"/> OTHER _____

LAND-EAST CONSTRUCTION CORP.	
P.O. BOX 180 CLAREMONT, N.H.	
TEL. 542-5159	ZIP CODE 03743
OWNERS NAME: TOWN SHEDS & GARAGE	
LOCATION: PLAINFIELD N.H.	SIZE PARCEL: 3 AC. +
SUBDIVISION NAME:	
SUBDIVISION APPROVAL NO.:	SUBDIVISION LOT NO.:
DRAWN BY: G.S. CLARK	DWG.# 74105
DATE: 6-11-74	

NOTE
THE WATER SUPPLY & POLLUTION CONTROL COMMISSION ADVISES THAT SEPTIC TANKS BE PUMPED OUT EVERY TWO YEARS TO HELP PROLONG THE LIFETIME OF THE LEACH AREA.

SCALE: 1" = 20'